



Fair  
Trading

File Ref: CS11063N  
Contact: Admin Clerk  
Telephone: 02 9895 0722

Ms Amy Brydon  
Selectronic Australia Pty Ltd  
C/- Approval Specialists Pty Ltd  
2/9 Packard Avenue  
CASTLE HILL NSW 2154

Dear Sir/Madam

CERTIFICATE OF SUITABILITY: CS11063N AND VARIATION/S

Inverter

Please find enclosed a Certificate of Suitability and addendum as sought by your application.

Articles of the approved type may be marked with the mark (or alternate approval mark) shown on the Certificate.

THE APPROVAL EXPIRES ON THE DATE SHOWN ON THE CERTIFICATE unless it is renewed, extended, suspended or cancelled.

Yours faithfully

3 March 2022

For Secretary, Department of Customer Service



Fair  
Trading

# Certificate of Suitability Non-Declared Article

Pursuant to Section 16 (1) of the Gas and Electricity  
(Consumer Safety) Act 2017

Certificate Number: **CS11063N**

This is to certify that the article specified below is accepted by NSW FAIR TRADING as suitable for connection to public electricity supply in NEW SOUTH WALES in accordance with the provisions of AS/NZS 3000 and subject to the condition stated.

Issued to:	Selectronic Australia Pty Ltd
Article:	Multi-Mode Interactive Inverter (Interactive Inverter Charger for off grid and grid connected application primarily for conversion of DC battery source to AC supply and recharging batteries when AC source available, not for PV direct connections, housed inside metallic enclosure.)
Trade Name or Mark:	Selectronic
Ratings:	AC Input: 210-240V, 50Hz, 63A, 1Ph DC Input/Output: 48V (40-68V) 83A Inverter Output: 240V, 50Hz, 14.6A, 3.5KVA Class I, IP43
Type Reference Code:	SPMC480-AU
Examined for Compliance With:	IEC 62109-1: 2010; IEC 62109-2: 2011; IEC62477-1:2012 + A1; AS/NZS 4777.2: 2020
Nominated Marking:	CS11063N or approved alternate mark
Date of Approval:	25/02/2022
Approval Expires:	25/02/2027 unless suspended, cancelled, renewed or extended

**Condition:**

1. This certificate is issued subject to the article and approved variations being maintained at the specification/s of the article examined at the time of approval.
2. For compliance with performance requirements refer to AUSTEST Laboratories, Test Report No. 0208SELSPMC\_47772 dated 08/02/2022

3 March 2022



On behalf of the Secretary, Department of Customer Service

For information regarding currency of model approval, refer to the Fair Trading Website